

MUNICIPAL CORPORATION JALANDHAR

WATER TESTING LABORATORY (WATER ANALYSIS REPORT)

REF. NO: -1288


REF. DATE: 18/05/26

Sample provided by :- Lala Jagat Narain D.A.V Model School, Lane 4, Kabir Nagar, Jalandhar

SR.NO	TEST	REQUIRED LIMIT IS10500	SAMPLE
1	COLOUR	5 Hazen	Colorless
2	ODOUR	Unobjectionable	Normal
3	TASTE	Agreeable	normal
4	PH	6.5 – 8.5	6.6
5	DISSOLVED SOLIDS (TDS)	500 ppm	59
6	TOTAL HARDNESS (as CaCO ₃)	300 mg/l	35
7	ALKALINITY	200 mg/l	30
8	CALCIUM (as Ca ⁺⁺)	75 mg/l	4.2
9	IRON	0.3 mg/l	0.1
10	CHLORIDE	250 mg/l	18
11	SULPHATES	150 mg/l	nil
12	NITRATES	4.5 mg/l	nil
13	FLOURIDE	1.0 mg/l	o.1
14	RESIDUAL CHLORINE	0.2 mg/l	nil
15	TOTAL COLLIFORM COUNT (by MPN method per 100ml)	NIL	nil

REMARKS :-

provided water sample found satisfactory as per applied tests



DATE:-20/05/26

Akshay Kumar
Analyst
MUNICIPAL CORPORATION JALANDHAR

ANALYST